



# **ExPro-C** Temperature/humidity sensor


connectable exclusively to transmitters ExCos-D and RedCos-D for measuring of temperature and/or humidity

### Subject to change!


Туре	Function	Range	Sensor length	Connection	Installation area sensor
ExPro-CT	Temperature sensor	-40+125 °C*	50 / 100 / 150 / 200 mm	Plug and socket to ExCos-D, RedCos-D	. Zone 1, 2, 21, 22
ExPro-CF	Humidity sensor	0100 % rH	50 / 100 / 150 / 200 mm	Plug and socket to ExCos-D, RedCos-D	. Zone 1, 2, 21, 22
ExPro-CTF	Combination sensor	-40+125 °C* / 0100 % rH	50 / 100 / 150 / 200 mm	Plug and socket to ExCos-D, RedCos-D	. Zone 1, 2, 21, 22
Sensor length		* at 50 mm length −40 <b>+80</b> °C	TTTT		

### **Product views and applications**

# ExPro-C... Fig.: Humidity sensors













Technical data	ExPro- CT	ExPro- CF	ExPro- CTF				
	Temperature sensor	Humidity sensor	Temperature / humidity sensor				
Measuring range	-40+125 °C *	0100 % rH	-40+125 °C * / 0100 % rH				
	* -40+80 °C at 50 mm length		* -40+80 °C at 50 mm length				
Sensor length	ExPro-CT- 50 = 50 mm	ExPro-CF- 50 = 50 mm	ExPro-CTF- 50 = 50 mm				
	ExPro-CT-100 = 100 mm	ExPro-CF-100 = 100 mm	ExPro-CTF-100 = 100 mm				
	ExPro-CT-150 = 150 mm	ExPro-CF-150 = 150 mm	ExPro-CTF-150 = 150 mm				
	ExPro-CT-200 = 200 mm	ExPro-CF-200 = 200 mm	ExPro-CTF-200 = 200 mm				
Response time sensor	T90 / 20 s	T90 / 4 s	T90 / 20 s, T90 / 4 s				
Accuracy temperature	±0,4 °C at 25 °C ±0,02 °C/°C						
Accuracy humidity	±3 % at 1090 % rH / ±5 % at < 10 % rH and > 90 % rH						
Housing protection	IP66 acc, to EN 60529						
Material Adapter	Stainless steel № 1.4305, length 50 mm in plastic PEEK-GF30 (max. room temperature +80 °C)						
Protection sleeve	Stainless steel № 1.4301 / AISI 304						
End cap	AISI 316						
Plug-in connector	Zinc die-cast nickel-plated, screw sleeve brass nickel-plated						
Filter element humidity sensor	Mesh size 100 μm						
Ambient temperature / humidity	−40+125 °C (−40+80 °C at 50 mm length) / 0100 % rH						
Storage temperature	−40+125 °C (−40+80 °C at 50 mm length)						
Installation area sensor	in Ex areas zone 1, 2, 21, 22						
Scope of delivery	ExPro-C sensor with plug-in connector and gasket (EPDM) for duct installation						

### Description

ExPro-C... sensor is a measuring element which is in combination with an ...Cos-D... transmitter for temperature, humidity or combination of temperature and humidity measuring. ExPro-C... sensors are only for use with ExCos-D.../RedCos-D... transmitters.

The electromechanical connection is done with a socket on the front resp. on the back side of the transmitter, but only 1 ExPro-C... per module is allowed and can be used. Warning: Aggressive gases can destroy the sensor element.

							٠.		
Α	C	C	е	S	S	٥	rı	e	S

MFK	Mounting flange for duct mounting for variable immersion depth in ducts
MKR	Mounting bracket for round ducts up to Ø 600 mm
TH-VA	Immersion sleeve in stainless steel V4A / DIN EN 1.4571, length 120 mm.
	Other length on request.
Kit-FA-VA	Stainless steel sinter filter cap for humidity sensors, pore size 10 µm.
	Not for high humidity measurements!
VL3	Sensor extension cable, 3 m, PVC

Schischek GmbH Germany, Muehlsteig 45, Gewerbegebiet Sued 5, 90579 Langenzenn, Tel. +49 9101 9081-0, Fax +49 9101 9081-77, E-Mail info-de@schischek.com


puh: +358 19-574 57 00 s-posti: info@malux.fi www.malux.fi







### Accuracy temperature and humidity incl. hysteresis



### Max. Medium temperature – Temperature class (surface temp.)

Temperature class	Т6	T5	T4	Т3	T2	T1
Max. medium temperature [°C]	60	75	110	125	125	125

### Important information for installation and operation

### A. ExPro-C... sensor

The power for ExPro-C... sensor is supplied via an instrinsically safe (IS) circuit from the transmitter. Unused sensor entries have to be closed with the black caps.

### B. Temperature flow

When measuring temperature over the max. allowed environmental temperature of the transmitter of +50 °C regard that no temperature flow over the sensor takes place. The mounting of the sensor has to ensure that errors due to heat dissipation are within the tolerance limits and the max. allowed environmental temperature is not exceeded.

### C. Mounting

Screw the sensor into the socket of the transmitter. The sensor cannot be opened as parts of the element are moulded. A small distance tolerance between transmitter and sensor has to be accepted due to production conditions.

### Intrinsically safe parameters

Jį	=	7,9 V	$C_{i}$	=	0	$P_i$	=	95 mW
l.	=	48 mA	1 .	=	0			

## Mounting room sensor (at terminal box side)





A small clearance between transmitter and sensor has to be accepted due to production conditions.





# Protection sleeve ExPro-C... -50 ...-100 ...-150 ...-200 End cap Protection sleeve Adapter Plug-in connector with screw sleeve

### Mounting duct sensor (back side)





For mounting the sensor must be plugged into the socket and screwed on the sensor by turning the lower knurled screw clockwise. Tighten hand-screwed only.

A small clearance between transmitter and sensor has to be accepted due to production conditions.

### MFK mounting flange for duct installation

The flange is to be moved over the sensor and fixed with the adjusting screw on the side. The flange can be mounted with 4 screws directly to the duct.



ExPro-C\_en 02 - 16-Aug-2016/

Schischek GmbH Germany, Muehlsteig 45, Gewerbegebiet Sued 5, 90579 Langenzenn, Tel. +49 9101 9081-0, Fax +49 9101 9081-77, E-Mail info-de@schischek.com



puh: +358 19-574 57 00 s-posti: info@malux.fi www.malux.fi

